| Estate | Fintry South West 2 | Date | 21 June 2023 | l 🕷 | |
|------------------------|---|--|--------------|--|------------------------|
| Date of next walkabout | 28 June 2023 | Number of Attendees | 2 | HUSINGASSOCIATION | |
| Street Name | Issue Identified | Action Agreed | Status | Notes | Actual Completion Date |
| Finavon Street | Tree at front right hand side of building getting overgrown | Speak to DL | 0 | To be considered during DL and BL Survey for next Tree Maintenance Programme. | |
| Finavon Street | 2 Fence spars needing replaced in rear green | Line raised for AB | 0 | | |
| Finavon Street | Broken rear door step | Line raised for WN | 0 | | |
| Finavon Street | 6 X6 Drain cover req | Line raised for CMc | 0 | | |
| Finavon Street | 1/R Blow off from boiler leaking and damaging harling (| Line raised for WRB to repair | 0 | | |
| Finavon Street | Rubbish dumped in drying green area | Line raised for s&s cleaning to uplift | 0 | | |
| Finavon Street | Materail on Side of riser on ground floor needing removed | Line raised for WN | 0 | | |
| Finavon Place | wire mesh fence needing repaired / top step needing reset | Lines raised for GW Wilson and WN | 0 | | |
| Finavon Street | Facia boarde etc needing attention | Speak to DL | 0 | | |
| Finavon Street | Riser on ground floor stairwell needing attetion | Line raised for WN | 0 | | |
| Finavon Street | Rhones on back porch req clearing out | Line raised for WN | 0 | | |
| Finavon Street | 6 x 6 Drain cover req left hand side of building | Line raised for CMc | 0 | | |
| Finavon Street | Riser on ground floor stairwell needing attetion / Old fence post needing dumped | Lines raised for WN | 0 | | |
| Finavon Street | 6 x Quarry tile broken | Line r5aised for WN | 0 | | |
| Finavon Street | Fridge freezer and old furniture dumped in close | Speak to GA | Complete | Letter sent to tenants | 06/07/2023 |
| Finavon Street | Top landing 1 stair tread req replacing | Line raised for SD | 0 | | |
| Finavon Street | Rubbish dumped in back green area | Speak to GA | Complete | Letter sent to tenants | 06/07/2023 |
| Finavon Street | 2 X Fence spars to replace 32 RH 34 LH | Line raised for SD | 0 | | |
| Finavon Street | Rubbish dumped in close and back green | Speak to GA | Complete | Letter sent to tenants | 06/07/2023 |
| Finavon Street | Close lights on during day | Line raised for DA | 0 | | |
| Finavon Street | Moss forming on tiles under all solar panels in street | Speak to DL | 0 | | |
| Finavon Street | Facia boards on front building needing attention | Speak to DL | 0 | | |
| Finavon Place | Chain link fence and steps needing repaired | Line raised for gw wilson & NG | 0 | | |
| Finavon Place | Chain link fence needing repaired / replaced | Line raised for GW Wilson | 0 | | |
| Finavon Place | Car tyres/ batterys etc and genral rubbish lying about back garden | Speak to GA | Complete | Letter sent to tenant | 06/07/2023 |
| Finavon Place | Chain link fence needing repaired / replaced | Line raised for GW Wilson | 0 | | |
| Finavon Place | Old bed etc lying in front garden | Speak to GA | Complete | Letter sent to tenant | 06/07/2023 |
| Finavon Place | Rubbish lying in garden at side of building | Speak to GA | С | Letter sent to tenant | 06/07/2023 |
| Fintry Road | Front and back gardens for flat are unkempt | Speak to GA | Complete | Letter sent to tenant | 06/07/2023 |
| Fintry Road | Plaster on riser needing attention | Line raised for WN | 0 | | |
| Fintry Road | Wire mesh fence in open plan area outside 5-7 fintry rd | Line raised for gw wilson | 0 | | |
| Fintry Road | Window handle on first floor broken | Line raised for sd | 0 | | |
| Fintry Road | 3 x gates in open plan mainteance area missing | Line raised for GW Wilson | 0 | | |

| Estate | Fintry South West 2 | Date | 21 June 2023 | l 🕷 |
|------------------------|--|---------------------------|--------------|--|
| Date of next walkabout | 28 June 2023 | Number of Attendees | 2 | HOUSINGASSOCIATION |
| Fintry Road | Wire mesh fence on path area between 5-7 needing repaired | Line raised for GW Wilson | 0 | |
| Fintry Road | Various back gardens on fintry rd in need of grass cutting etc | Speak to DL | 0 | Dean has e-mail OSM management team and the Contractor's Supervisor for action the next time they are on site. |
| Finavon Terrace | Wire mesh fence needing reaired / replaced | Line raised for GW Wilson | 0 | |
| Finavon Terrace | Tree in front garden needing checked Very overgrown | Speak to DL | 0 | To be considered during DL and BL Survey for next Tree Maintenance Programme. |